

23RD ANNUAL PQSYNERGY INTERNATIONAL CONFERENCE AND EXHIBITION 2025



AISSMS
INSTITUTE OF INFORMATION TECHNOLOGY
(IOIT)



ADDING VALUE TO ENGINEERING

An Autonomous Institute Affiliated to Savitribai Phule Pune University
Approved by AICTE, New Delhi and Recognised by Govt. of Maharashtra
Accredited by NAAC with "A+" Grade | NBA - 5 UG Programmes

DEVELOPMENT OF POWER QUALITY MONITORING SYSTEM FOR COMPLIANCE WITH PQ REGULATIONS IN MAHARASHTRA STATE (INDIA) : CASE STUDY OF AISSMS IOIT CAMPUS

MONDAY, 08 SEPTEMBER 2025



Sachin Shelar
Head – Power Quality Cell
Asst. Professor
Department of Electrical Engineering
AISSMS IOIT, Pune



Co-Authors

Dr. Deepak Bankar (Bharati Vidyapeeth (Deemed to be University) College of Engineering, Pune, India)

Hari Balasubramanian (Janitza Electronics, Chennai, India)



Brief Profile : **Prof. Sachin Shelar**



- B.E. Electrical (**Gold Medalist**) **1998**
- M.E. (Power System)(**First Rank**) COEP **2004**
- Ph.D. (**Power Quality**) Pursuing
- **Head of Power Quality Cell (Dept. of Electrical Engg, AISSMS IOIT, Pune)**
- **Member (Co-opt) BIS** - Electromagnetic Compatibility Sectional Committee (LITD 09)
- **Member IEC TR 63222-102** - Developing Networks toward Power Quality Standards
- **3 Years Industrial & 25 Years teaching** experience
- Conducted more than **400+ Power Quality audits**.
- **Ex. Chairman** of the subject “**Power Quality Management**” (**Savitribai Phule Pune University**)
- Published over **30 papers** at national and international level and has authored **3 books**
- Recently established state-of-the-art “**D. M. Tagare Power Quality Experience Center**” worth ₹ **1.5 Crore** at AISSMS's IOIT Pune.

This Power Quality Center is the first of its kind in India.

Contents

Power Quality **Monitoring**

PQ Regulations in India

Maharashtra State PQ Regulation

Introduction to Case Study

Hardware - **Class A PQ meter**

Software for PQ monitoring

Results (**Dashboards**)

**What you don't know
is hurting you !**

“Proverb”



PQ Monitoring

Power quality monitoring is the **process of gathering, analyzing, and interpreting raw measurement data** into **useful information**

PQ Monitoring Considerations

Characterize system performance
(**Benchmarking / Compliance**)

Characterize specific problems

Predictive or just-in-time maintenance

PQ Regulations / Standard in India (As on Aug 2025)

Forum of Regulators

- **August 2018**
- Model Regulation on Power Quality for State

Central Electricity Authority

- **February 2019**
- Technical Standards for Connectivity to the Grid regulations

Indian Standard

- **IS 17036 : 2018**

- Distribution System Supply **Voltage Quality**

Assam State

- **Feb. 2020 (Draft)**

- Draft Assam Electricity Regulatory Commission (**Power Quality** for Distribution System) Regulations, 2020

Maharashtra State

- **Feb. 2021**

- Electricity Supply Code and Standards of Performance of Distribution Licensees Including **Power Quality** Regulations 2021"

Indian Standard

- **IS 18475 : 2023**

- **Power Quality** Measurement and Monitoring - Methods

Punjab State

- **March 2023**

- Punjab State Electricity Regulatory Commission (**Power Quality**) Regulations, 2023

Tamilnadu State

- **July 2024 (Draft)**

- Draft amendments to the Tamil Nadu Electricity Supply Code

Madhya Pradesh State

- **Jan. 2025**

- Madhya Pradesh State Electricity Regulatory Commission (**Power Quality**) Regulations, 2025

Karnataka State

- **Jan. 2025 (Draft)**

- Draft Karnataka Electricity Distribution Code (KEDC), 2024

Maharashtra State PQ Regulations (Feb 2021)



Distribution Licensee

1. Supply voltage **variations**
2. Supply voltage **flicker**
3. Supply voltage **unbalance**
4. Supply voltage **dips** and **swells**
5. Supply voltage individual **harmonics** and voltage **THD**
6. Supply **Interruptions**

Designated Consumers

1. Current individual **harmonics** and current **TDD**

Supply Voltage Variation

Table 1: Supply Voltage Variation Limits for Low Voltage and High Voltage

Supply Voltage Characteristic	Reference Time Frame	Limits
Mean r.m.s. value of the supply voltage over 10 min	100% of time	$U_n + 10 \% / -15 \%$

Table 2: Supply Voltage Variation Limits for Extra-high Voltage

Supply Voltage Characteristic	Reference Time Frame	Limits
Mean r.m.s. value of the supply voltage over 10 Min	100% of time	As specified by Central Electricity Authority/CERC

For statistical evaluation, voltage variations shall be assessed for the period not less than 7 continuous days.

Supply Voltage **Flicker**

Maharashtra
State PQ
Regulations
(Feb 2021)

Supply Voltage Characteristic	Reference Time Frame	Limits
Long Term flicker severity P_{lt} caused by voltage fluctuation	95% of each period of one week	≤ 1

Supply Voltage **Unbalance**

Maharashtra
State PQ
Regulations
(Feb 2021)

Supply Voltage Characteristic	Reference Time Frame	Limits
Ratio of r.m.s value of negative phase sequence component (fundamental) to the r.m.s value of positive phase sequence component (fundamental) of the supply voltage	95% of each period of one week	≤ 2 percent

Supply Voltage dips (Sag)

280

Number of Events per Year

Residual Voltage (%)	Duration t (ms)				
	$10 \leq t \leq 200$	$200 < t \leq 500$	$500 < t \leq 1000$	$1000 < t \leq 5000$	$5000 < t \leq 60000$
$90 > u \geq 80$	30	40	10	5	5
$80 > u \geq 70$	30	40	5	5	5
$70 > u \geq 40$	10	40	5	5	5
$40 > u \geq 5$	5	20	5	5	5

Short Voltage Interruptions

75

Residual Voltage (%)	Duration t (ms)				
	$10 \leq t \leq 200$	$200 < t \leq 500$	$500 < t \leq 1000$	$1000 < t \leq 5000$	$5000 < t \leq 180000$
$5 > u$	5	20	30	10	10

Short Voltage Harmonics

[As per IS 17036]

Maharashtra
State PQ
Regulations
(Feb 2021)

Supply Voltage Characteristic	Reference Time Frame	Limits
Mean root mean square (r.m.s.) values of each individual harmonic voltage measured over 10 min	95 percent of each period of one week	See Table 10
	Remaining 5 percent of time	No limits
THD	100 percent of time	≤ 8 percent

Table 10 Values of Individual Harmonic Voltages of the Supply Voltage in Percent of the Fundamental Voltage (U₁)

Odd Multiple of Harmonics (Percent)								Even Harmonics (Percent)			
Not Multiples of 3				Odd Multiples of 3							
h (harmonic order)	LV	MV	HV	h (harmonic order)	LV	MV	HV	h (harmonic order)	LV	MV	HV
5	6	6	5	3	5	5	3	2	2	2	1.9
7	5	5	4	9	1.5	1.5	1.3	4	1	1	1
11	3.5	3.5	3	15	0.5	0.5	0.5	6 to 24	0.5	0.5	0.5
13	3	3	2.5	21	0.5	0.5	0.5				
17	2	2									
19	1.5	1.5									
23	1.5	1.5									
25	1.5	1.5									

Recommended Minimum **Assessment Periods** and **Frequency of Reporting**

IS 18475 : 2023

**Power Quality
Measurement
and
Monitoring —
Methods**

Sl No.	Parameter	Minimum Assessment Period	Recommended Frequency of Reporting to Authorities
(1)	(2)	(3)	(4)
i)	Supply frequency	1 week	Quarterly
ii)	Magnitude of supply voltage	1 week	Monthly
iii)	Single rapid voltage change	Under consideration	Under consideration
iv)	Flicker	1 week	Quarterly
v)	Supply voltage unbalance	1 week	Quarterly
vi)	Harmonic voltages	1 week	Quarterly
vii)	Interharmonic voltages	Under consideration	Under consideration
viii)	Main signalling voltages	1 day	Quarterly
ix)	Voltage interruptions	1 year	Yearly with monthly sliding window
x)	Dips and swells	1 year	Yearly with monthly sliding window
xi)	Magnitude of current	1 week	Quarterly
xii)	Current unbalance	1 week	Quarterly
xiii)	Current harmonic	1 week	Quarterly
xiv)	Current inter-harmonic	Under consideration	Under consideration

Current individual harmonics and current TDD

[As per IEEE 519]

Maximum harmonic current distortion in percent of I_L

Individual harmonic order^b

I_{sc}/I_L	$2 \leq h < 11^a$	$11 \leq h < 17$	$17 \leq h < 23$	$23 \leq h < 35$	$35 \leq h \leq 50$	TDD
$< 20^c$	4.0	2.0	1.5	0.6	0.3	5.0
$20 < 50$	7.0	3.5	2.5	1.0	0.5	8.0
$50 < 100$	10.0	4.5	4.0	1.5	0.7	12.0
$100 < 1000$	12.0	5.5	5.0	2.0	1.0	15.0
> 1000	15.0	7.0	6.0	2.5	1.4	20.0

Case Study

PQ Monitoring System at

AISSMS Institute of
Information Technology,
Pune (India)






AISSMS
ALL INDIA SHRI SHIVAJI MEMORIAL SOCIETY
PREMIER HERITAGE GROUP OF INSTITUTES



Premier Heritage Group of Institutes (Est. 1917)



PQ Monitoring Architecture



Class A PQ Meter



Measurement process
in accordance with **IEC
61000-4-30 : Class A**

Continuous sampling
of the voltage and
current measurement
inputs at **25.6 kHz (512
Samples per cycle)**

Harmonics analysis up
to the **63rd harmonic**,
even / odd absolute
value

Distortion factor **THD-
U / THD-I / TDD**
(Calculated /
measured in meter)

Flicker measurement
in accordance with DIN
EN 61000-4-15

Short-term
interruptions (**> 10 ms**)

Configurable memory
including 3 sec (as per
IEEE 519)

Logging and storage of
transients (**> 39 μ s**)

High resolution colour
graphical display 320 x
240, 256 colours, 6
buttons

PQ Analysis Software

Janitza®



GridVis® Expert

Energy management

Certified according to ISO 50001.

24/7 Energy Monitoring

Clear and customized Dashboards




Customize Reports

Safety & Alarm management

Network analysis & Evaluation

Connectivity













PQ Dashboards



AISSMS Campus Dashboard

8/23/2025

8:43 AM






AISSMS SLD Live Dashboard

8/26/2025

1:13 PM

S (Active Power)

187 kVA



Q (Reactive Power)

0 kvar

P (Active Power)

186 kW

Janitza UMG 512



TDD %



Current (A)

23.48 A

Temp (C)

44.00

Comsys ADF 75 Amp



Consumed kWh

1,197 kWh

Supplied kWh

0 kWh

Total kWh

1,586 kWh

Solar kWh

388 kWh

Today's Event List

Today: 26/08/2025, 00:00 - 26/08/2025, 13:13

Type	Pha
Under voltage	Mai
Under voltage	L1
Under voltage	L2L
Under voltage	L3L
Under voltage	L3
Under voltage	L1L
Under voltage	L2
Under voltage	L3
Under voltage	Mai
Under voltage	L1L
Under voltage	L3L
Slope	L1
Slope	L1
Slope	L1
Slope	L2

34 entries total

15 < 1 2 3 >

11.69 %

Power (kW)

66 kW

COE (150 kW)

33.38 kW

IOIT (100 kW)

21.66 kW

COP (50 kW)

11.49 kW

300 kW Solar Plant



Power (kW)

188.10 kW

AISSMS COE



Power (kW)

55.12 kW

AISSMS IOIT



Power (kW)

33 kW

AISSMS COP



Power (kW)

33 kW

AISSMS Poly



Power (kW)

33 kW

AISSMS MBA



Power (kW)

33 kW

AISSMS School



THD 9.18 % 6.57 % TDD

8.99 %

Total Load (kW)












252 kW



AISSMS Live Dashboard

8/26/2025

1:13 PM






AISSMS Solar Live Dashboard

8/26/2025






1:14 PM



12.03 %

Yesterday's Generation (kWh)
674 kWh
Yesterday: 25/08/2025, 00:00 - 26/08/2025, 00:00

Today's Generation (kWh)
388.35 kWh
Today: 26/08/2025, 00:00 - 26/08/2025, 13:13



Historical Dashboards





AISSMS Solar Heatmap Dashboard

8/26/2025

1:14 PM

Last Years Generation (kWh)	This Year Generation (kWh)	Last Month's Generation (kWh)	This Month's Generation (kWh)	Yesterday's Generation (kWh)	Today's Generation (kWh)
113,749 kWh	221,320 kWh	23,991 kWh	19,967 kWh	674 kWh	388 kWh
Last year: 01/01/2024, 00:00 - 01/01/2025, 00:00 There are only about 32% of raw data in the chosen time range.	This year: 01/01/2025, 00:00 - 26/08/2025, 13:14	Last month: 01/07/2025, 00:00 - 01/08/2025, 00:00	This month: 01/08/2025, 00:00 - 26/08/2025, 13:14	Yesterday: 25/08/2025, 00:00 - 26/08/2025, 00:00	Today: 26/08/2025, 00:00 - 26/08/2025, 13:14






AISSMS PQ (Voltage) Dashboard

8/23/2025


8:46 AM



Event List
Last 14 completed days: 09/08/2025, 00:00 - 23/08/2025, 00:00

Type	Phase	Start	Duration
E Under voltage	L3	08/20/2025, 02:29:51...	230 ms
E Under voltage	L2	08/20/2025, 02:29:51...	170 ms
E Under voltage	L1	08/20/2025, 02:29:51...	170 ms
E Under voltage	L3	08/14/2025, 05:43:21...	150 ms
E Under voltage	L2	08/09/2025, 10:59:02...	150 ms
E Under voltage	L2	08/14/2025, 05:43:21...	140 ms
E Under voltage	L3	08/09/2025, 10:59:02...	130 ms
E Under voltage	L1	08/14/2025, 05:43:21...	120 ms
E Under voltage	L2	08/19/2025, 03:22:14...	120 ms
E Under voltage	L3	08/19/2025, 03:22:14...	120 ms
E Under voltage	L2	08/19/2025, 03:39:33...	110 ms
E Under voltage	L3	08/20/2025, 05:01:40...	110 ms
E Under voltage	L2	08/18/2025, 05:24:55...	100 ms
E Under voltage	L2	08/19/2025, 01:27:19...	100 ms
E Under voltage	L2	08/21/2025, 03:13:03...	100 ms

1507 entries total






AISSMS PQ (Current) Dashboard

8/23/2025

8:49 AM

Current Profile

Last 7 completed days: 16/08/2025, 00:00 - 23/08/2025, 00:00




Current Summary

Last 7 completed days: 16/08/2025, 00:00 - 23/08/2025, 00:00

Date	R Phase [AVG]	R Phase [MAX]	Y Phase [AVG]	Y Phase [MAX]	B Phase [AVG]	B Phase [MAX]	Neutral [AVG]	Neutral [MAX]
Sat, 08/16/2025	78 A	151 A	74 A	140 A	63 A	136 A	53 A	87 A
Sun, 08/17/2025	87 A	349 A	84 A	361 A	78 A	368 A	53 A	72 A
Mon, 08/18/2025	175 A	389 A	156 A	360 A	148 A	340 A	63 A	138 A
Tue, 08/19/2025	208 A	489 A	187 A	414 A	177 A	396 A	66 A	133 A
Wed, 08/20/2025	181 A	454 A	157 A	408 A	151 A	385 A	66 A	160 A
Thu, 08/21/2025	156 A	413 A	131 A	372 A	126 A	349 A	65 A	132 A
Fri, 08/22/2025	⚠️ 168 A	⚠️ 381 A	⚠️ 140 A	⚠️ 310 A	⚠️ 137 A	⚠️ 332 A	⚠️ 66 A	⚠️ 149 A

Current Heat Map

Last 7 completed days: 16/08/2025, 00:00 - 23/08/2025, 00:00



8/23/2025 8:51 AM



AISSMS Power Dashboard

Active Power & Reactive Power Variation

Last 7 completed days: 16/08/2025, 00:00 - 23/08/2025, 00:00



Power Summary

Last 7 completed days: 16/08/2025, 00:00 - 23/08/2025, 00:00

Date	P (kW) [MIN]	P (kW) [AVG]	P (kW) [MAX]	Q (kVar) [MIN]	Q (kVar) [MIN]	Q (kVar) [MAX]	S (kVA) [MIN]	S (kVA) [AVG]	S (kVA) [MAX]
Sat, 08/16/2025	-82.63 kW	39.37 kW	87.32 kW	-21.97 kvar	-21.97 kvar	32.16 kvar	11.83 kVA	50.42 kVA	94.03 kVA
Sun, 08/17/2025	-249.44 kW	25.55 kW	104.23 kW	-20.28 kvar	-20.28 kvar	27.81 kvar	16.13 kVA	58.19 kVA	249.92 kVA
Mon, 08/18/2025	38.81 kW	107.24 kW	234.52 kW	-24.89 kvar	-24.89 kvar	23.30 kvar	40.92 kVA	109.51 kVA	235.89 kVA
Tue, 08/19/2025	54.23 kW	129.16 kW	284.81 kW	-32.04 kvar	-32.04 kvar	33.29 kvar	57.71 kVA	131.43 kVA	287.03 kVA
Wed, 08/20/2025	-11.70 kW	109.44 kW	268.76 kW	-30.48 kvar	-30.48 kvar	29.59 kvar	0.00 kVA	111.78 kVA	270.21 kVA
Thu, 08/21/2025	-65.19 kW	92.18 kW	250.91 kW	-17.69 kvar	-17.69 kvar	26.21 kvar	18.32 kVA	95.75 kVA	252.18 kVA
Fri, 08/22/2025	⚠️ -77.57 kW	⚠️ 98.59 kW	⚠️ 234.05 kW	⚠️ -26.60 kvar	⚠️ -26.60 kvar	⚠️ 31.59 kvar	⚠️ 23.36 kVA	⚠️ 102.33 kVA	⚠️ 235.06 kVA


Distortion Power

Last 7 completed days: 16/08/2025, 00:00 - 23/08/2025, 00:00



Heat Map

Last 7 completed days: 16/08/2025, 00:00 - 23/08/2025, 00:00



08/16/2025 08/17/2025 08/18/2025 08/19/2025 08/20/2025 08/21/2025 08/22/2025


Legend: P (kW) [Active Power Sum L1-L3]
-148.33 kW 47.94 kW 244.21 kW



AISSMS Energy Dashboard

8/23/2025

8:55 AM





AISSMS Consumption Analysis (Monthly)

AISSMS Campus Main Incomer 08/01/2025, 12:00 AM - 08/23/2025.

8/23/2025

8:56 AM

This Month Copy				
Date	MSEDCL (Consumed)	Solar (Generated)	Solar (Supplied)	AISSMS (Total)
Tue, 07/01/2025	1,971 kWh	853 kWh	1 kWh	2,823 kWh
Wed, 07/02/2025	2,262 kWh	610 kWh	0 kWh	2,872 kWh
Thu, 07/03/2025	2,070 kWh	792 kWh	0 kWh	2,862 kWh
Fri, 07/04/2025	1,982 kWh	844 kWh	4 kWh	2,822 kWh
Sat, 07/05/2025	982 kWh	592 kWh	55 kWh	1,519 kWh
Sun, 07/06/2025	867 kWh	568 kWh	104 kWh	1,331 kWh
Mon, 07/07/2025	2,124 kWh	751 kWh	0 kWh	2,874 kWh
Tue, 07/08/2025	2,247 kWh	727 kWh	0 kWh	2,974 kWh
Wed, 07/09/2025	2,132 kWh	815 kWh	0 kWh	2,948 kWh
Thu, 07/10/2025	1,778 kWh	1,028 kWh	4 kWh	2,802 kWh
Fri, 07/11/2025	1,984 kWh	906 kWh	0 kWh	2,890 kWh
Sat, 07/12/2025	849 kWh	1,130 kWh	437 kWh	1,542 kWh
Sun, 07/13/2025	779 kWh	953 kWh	341 kWh	1,391 kWh
Mon, 07/14/2025	2,266 kWh	824 kWh	1 kWh	3,089 kWh
Tue, 07/15/2025	2,632 kWh	506 kWh	0 kWh	3,138 kWh
Wed, 07/16/2025	1,921 kWh	1,078 kWh	5 kWh	2,995 kWh
Thu, 07/17/2025	2,021 kWh	1,072 kWh	0 kWh	3,093 kWh
Fri, 07/18/2025	2,148 kWh	868 kWh	0 kWh	3,016 kWh
Sat, 07/19/2025	886 kWh	983 kWh	297 kWh	1,571 kWh
Sun, 07/20/2025	846 kWh	738 kWh	202 kWh	1,381 kWh
Mon, 07/21/2025	2,230 kWh	924 kWh	0 kWh	3,154 kWh
Tue, 07/22/2025	2,563 kWh	727 kWh	0 kWh	3,290 kWh
Wed, 07/23/2025	2,424 kWh	707 kWh	0 kWh	3,131 kWh
Thu, 07/24/2025	2,801 kWh	442 kWh	0 kWh	3,243 kWh
Fri, 07/25/2025	2,551 kWh	498 kWh	0 kWh	3,048 kWh
Sat, 07/26/2025	1,117 kWh	554 kWh	62 kWh	1,609 kWh
Sun, 07/27/2025	841 kWh	768 kWh	260 kWh	1,349 kWh
Mon, 07/28/2025	2,155 kWh	794 kWh	5 kWh	2,945 kWh
Tue, 07/29/2025	2,190 kWh	841 kWh	0 kWh	3,031 kWh
Wed, 07/30/2025	2,533 kWh	511 kWh	0 kWh	3,044 kWh
Thu, 07/31/2025	2,450 kWh	587 kWh	0 kWh	3,037 kWh
Total	58,600 kWh	23,991 kWh	1,781 kWh	80,811 kWh

This Month				
Date	MSEDCL (Consumed)	Solar (Generated)	Solar (Supplied)	AISSMS (Total)
Fri, 08/01/2025	2,021 kWh	928 kWh	0 kWh	2,948 kWh
Sat, 08/02/2025	1,116 kWh	872 kWh	139 kWh	1,849 kWh
Sun, 08/03/2025	955 kWh	1,078 kWh	357 kWh	1,676 kWh
Mon, 08/04/2025	2,383 kWh	839 kWh	0 kWh	3,221 kWh
Tue, 08/05/2025	2,135 kWh	1,119 kWh	0 kWh	3,254 kWh
Wed, 08/06/2025	2,401 kWh	606 kWh	0 kWh	3,007 kWh
Thu, 08/07/2025	2,363 kWh	910 kWh	0 kWh	3,273 kWh
Fri, 08/08/2025	2,350 kWh	541 kWh	0 kWh	2,891 kWh
Sat, 08/09/2025	973 kWh	802 kWh	238 kWh	1,537 kWh
Sun, 08/10/2025	794 kWh	1,032 kWh	493 kWh	1,334 kWh
Mon, 08/11/2025	1,846 kWh	1,359 kWh	0 kWh	3,205 kWh
Tue, 08/12/2025	2,175 kWh	1,049 kWh	0 kWh	3,223 kWh
Wed, 08/13/2025	2,509 kWh	631 kWh	0 kWh	3,139 kWh
Thu, 08/14/2025	2,184 kWh	773 kWh	2 kWh	2,955 kWh
Fri, 08/15/2025	▲ 969 kWh	582 kWh	▲ 78 kWh	1,473 kWh
Sat, 08/16/2025	964 kWh	609 kWh	73 kWh	1,500 kWh
Sun, 08/17/2025	897 kWh	872 kWh	340 kWh	1,430 kWh
Mon, 08/18/2025	2,593 kWh	434 kWh	0 kWh	3,028 kWh
Tue, 08/19/2025	3,030 kWh	248 kWh	0 kWh	3,278 kWh
Wed, 08/20/2025	2,551 kWh	530 kWh	0 kWh	3,081 kWh
Thu, 08/21/2025	2,153 kWh	898 kWh	4 kWh	3,047 kWh
Fri, 08/22/2025	▲ 1,608 kWh	▲ 734 kWh	▲ 11 kWh	2,331 kWh
Sat, 08/23/2025	-	-	-	0 kWh
Total	▲ 40,971 kWh	▲ 17,446 kWh	▲ 1,735 kWh	56,682 kWh

Today

⓪ No data available for

Yesterday

1,608 kWh

This Week

12,199 kWh

Last Week

11,906 kWh

This Month

42,271 kWh

Last Month

60,326 kWh

This Year

443,768 kWh

Last Year





372,630 kWh







AISSMS PQ (Harmonics) (Last 7 Days) Dashboard

8/23/2025

8:57 AM




AISSMS Overall PQ Health (Last 30 Days) Dashboard 8/23/2025 9:01 AM



Distortion Power
This year: 01/01/2025, 00:00 - 23/06/2025, 00:58

Date	R Phase [AVG]	Y Phase [AVG]	B Phase [AVG]
January	4.03 kvar	3.91 kvar	3.88 kvar
February	3.87 kvar	3.81 kvar	3.85 kvar
March	4.36 kvar	4.29 kvar	4.18 kvar
April	5.63 kvar	5.48 kvar	4.89 kvar
May	6.61 kvar	5.81 kvar	4.86 kvar
June	6.75 kvar	6.66 kvar	4.82 kvar
July	6.35 kvar	6.45 kvar	4.62 kvar
August	6.76 kvar	6.70 kvar	4.76 kvar



Event List
Last 30 completed days: 24/07/2025, 00:00 - 23/08/2025, 00:00

Type	Phase	Start	Duration	Value
Under voltage	L3	07/27/2025, 06:32:20...	290 ms	194.4 (MIN)
Under voltage	L3	08/20/2025, 02:29:51...	230 ms	198.7 (MIN)
Under voltage	L2	08/20/2025, 02:29:51...	170 ms	198.7 (MIN)
Under voltage	L1	08/20/2025, 02:29:51...	170 ms	200.3 (MIN)
Under voltage	L3	08/14/2025, 05:43:21...	150 ms	195.5 (MIN)
Under voltage	L2	08/09/2025, 10:59:02...	150 ms	140.5 (MIN)
Under voltage	L2	08/14/2025, 05:43:21...	140 ms	195.6 (MIN)
Under voltage	L3	08/09/2025, 10:59:02...	130 ms	188.3 (MIN)
Under voltage	L3	07/30/2025, 11:26:08...	130 ms	136.4 (MIN)
Under voltage	L1	08/14/2025, 05:43:21...	120 ms	198.4 (MIN)
Under voltage	L2	08/19/2025, 03:22:14...	120 ms	144.5 (MIN)
Under voltage	L3	08/19/2025, 03:22:14...	120 ms	135.7 (MIN)
Under voltage	L2	08/19/2025, 03:39:33...	110 ms	201.2 (MIN)
Under voltage	L2	08/03/2025, 12:59:53...	110 ms	66.9 (MIN)
Under voltage	L3	08/20/2025, 05:01:40...	110 ms	153.1 (MIN)
Under voltage	L2	08/18/2025, 05:24:55...	100 ms	197.8 (MIN)
Under voltage	L1	08/03/2025, 12:59:53...	100 ms	64.3 (MIN)
Under voltage	L3	08/03/2025, 12:59:53...	100 ms	62.3 (MIN)
Under voltage	L1	08/02/2025, 04:53:30...	100 ms	161.3 (MIN)
Under voltage	L1	07/25/2025, 12:57:20...	100 ms	182.1 (MIN)
Under voltage	L2	08/19/2025, 01:27:19...	100 ms	147.7 (MIN)
Under voltage	L1	07/26/2025, 09:41:07...	100 ms	144.9 (MIN)
Under voltage	L2	08/21/2025, 03:13:03...	100 ms	191.4 (MIN)
Under voltage	L3	08/19/2025, 01:27:19...	100 ms	140 (MIN)
Under voltage	L1	08/08/2025, 08:24:54...	100 ms	81 (MIN)
Under voltage	L2	07/30/2025, 11:26:09...	100 ms	197.5 (MIN)
Under voltage	L2	08/09/2025, 12:26:38...	100 ms	177 (MIN)
Under voltage	L1	08/09/2025, 12:26:38...	100 ms	187.1 (MIN)
Under voltage	L1	08/17/2025, 07:16:34...	91 ms	205.3 (MIN)
Under voltage	L3	07/30/2025, 04:26:23...	90 ms	203.3 (MIN)

91 entries total



PQ Events - ITIC (Last 14 Days) Dashboard

8/23/2025


8:58 AM

Type	Phase	Start	Duration	Value
Under voltage	L3	08/20/2025, 02...	230 ms	198.7 (MIN)
Under voltage	L2	08/20/2025, 02...	170 ms	198.7 (MIN)
Under voltage	L1	08/20/2025, 02...	170 ms	200.3 (MIN)
Under voltage	L3	08/14/2025, 05...	150 ms	195.5 (MIN)
Under voltage	L2	08/09/2025, 10...	150 ms	140.5 (MIN)
Under voltage	L2	08/14/2025, 05...	140 ms	195.6 (MIN)
Under voltage	L3	08/09/2025, 10...	130 ms	188.3 (MIN)
Under voltage	L1	08/14/2025, 05...	120 ms	198.4 (MIN)
Under voltage	L2	08/19/2025, 03...	120 ms	144.5 (MIN)
Under voltage	L3	08/19/2025, 03...	120 ms	135.7 (MIN)
Under voltage	L2	08/19/2025, 03...	110 ms	201.2 (MIN)
Under voltage	L3	08/20/2025, 05...	110 ms	153.1 (MIN)
Under voltage	L2	08/18/2025, 05...	100 ms	197.8 (MIN)
Under voltage	L2	08/19/2025, 01...	100 ms	147.7 (MIN)
Under voltage	L2	08/21/2025, 03...	100 ms	191.4 (MIN)
Under voltage	L3	08/19/2025, 01...	100 ms	140 (MIN)
Under voltage	L2	08/09/2025, 12...	100 ms	177 (MIN)
Under voltage	L1	08/09/2025, 12...	100 ms	187.1 (MIN)
Under voltage	L1	08/17/2025, 07...	91 ms	205.3 (MIN)
Under voltage	L1	08/19/2025, 01...	90 ms	146.6 (MIN)
Under voltage	L2	08/17/2025, 03...	90 ms	176.2 (MIN)
Under voltage	L1	08/19/2025, 09...	80 ms	89.2 (MIN)
Under voltage	L2	08/18/2025, 03...	80 ms	156.4 (MIN)
Under voltage	L3	08/18/2025, 04...	70 ms	151.8 (MIN)
Under voltage	L3	08/19/2025, 09...	70 ms	64.4 (MIN)
Under voltage	L1	08/19/2025, 03...	70 ms	139.2 (MIN)
Under voltage	L2	08/09/2025, 12...	70 ms	197.9 (MIN)
Under voltage	L2	08/09/2025, 12...	70 ms	205.3 (MIN)
Under voltage	L1	08/20/2025, 05...	70 ms	158.2 (MIN)

45 entries total

60

1






Maharashtra PQ Regulation 2021 Compliance AISSMS

08/16/2025, 12:00 AM - 08/23/2025, 12:00 AM

V-RY [10 min Avg] (352.75 to 456.5 Volts)



V R-Y [10-minute average]

V-YB [10 min Avg] (352.75 to 456.5 Volts)



V Y-B [10-minute average]


V-BR [10 min Avg] (352.75 to 456.5 Volts)



V R-B [10-minute average]

R-Ph Plt (< 1)


0.42



R-Ph Flicker Plt

Y-Ph Plt (< 1)

0.49



Y-Ph Flicker Plt

B-Ph Plt (< 1)


0.46



B-Ph Flicker Plt

Supply Voltage Unbalance (< 2%)

0.56 %



Unbalanced Voltage (%)

Clause 22.5. - Supply Voltage Variation Compliance (Last Week)

Mean r.m.s. value of the supply voltage over 10 minutes (352.75 to 456.5 Volts)

Overall: Pass

Supply Voltage Dips [1 Year <=280]



4%

Voltage Sags: 10/280 (4%)

Short Voltage Interruptions [1 Year <=75]


Last 7 completed days: 16/08/2025, 00:00 - 23/08/2025, 00:00




No data available for the selected time range

Error fetching event count.

Individual Harmonic Current % [10 min Avg]



Individual Harmonic Vol. [10 min Avg] (5<5%|7<6%|11<3.5%|13<3%|17<2%)



Current Harmonic [10 min Avg] (100% <= 8%)

Date	R - TDD (%) [AVG]	Y - TDD (%) [AVG]	B - TDD (%) [AVG]
CW 33 2025	7.27 %	7.36 %	4.21 %
CW 34 2025	6.86 %	7.05 %	5.27 %

Clause 22.13 - TDD Compliance

As per IEEE 519-2014 (<8%)

Overall: Pass

Supply Voltage Harmonic [10 min Avg] (100% <= 8%)

Date	R THD(%) [AVG]	Y THD(%) [AVG]	B THD(%) [AVG]
CW 33 2025	1.78 %	1.97 %	1.92 %
CW 34 2025	1.81 %	1.94 %	1.90 %

Clause 22.11 - Voltage THD Compliance

As per IS 17036 (<8%)

Overall: Pass

Enhanced Power Quality Report - IEEE 519 -2022

Customer

Name: AISSMS
Company: AISSMS RTO Campus Pune
Location: Main Incomer (3 Phase) LT Side

Auditor

Name: Prof. Sachin Shelar
Company: Power Quality Cell (AISSMS IOIT Pune)

Start date: 18/08/2025, 00:00
End date: 24/08/2025, 23:59
Date: 31/08/2025, 14:48
Software: Janitza-GridVis 9.2.4(206)



Measurement Point: AISSMS Campus Main Incomer
Serial Number: 4201-2781
Device type: UMG 512
Flicker: Supported
Events: Supported
Transients: Supported

Configuration

ISC/IL ratio: 20 < ratio <= 50 (1 to 2 large customers)
Value: Current
Timebase: Short Time (10 min)
Percentile: 99th percentile

	Minimum	Maximum	Result	recording gap
TDD [%] R Phase	3.21 %	10.07 %	Passed	2.03%
TDD [%] Y Phase	3.68 %	11.28 %	Passed	2.03%
TDD [%] B Phase	2.96 %	9.40 %	Passed	2.03%


IEEE 519 Compliance

Limits

Lower limit	0.00
Higher limit	12.00
Percentage	99.00%

Results

Min value	3.21 %
Average value	7.07 %
Max value	10.07 %
Total Values	990
Total out	0 (0.00%)
Overcut	0 (0.00%)
Undercut	0 (0.00%)
Recording vacancy	2.03%
Result	Passed



TDD [%] R Phase (10m) [AISSMS Campus Main Incomer]
Marker Lower limit
Marker Higher limit



AISSMS **INSTITUTE OF INFORMATION TECHNOLOGY** **(IOIT)**



ADDING VALUE TO ENGINEERING

An Autonomous Institute Affiliated to Savitribai Phule Pune University
Approved by AICTE, New Delhi and Recognised by Govt. of Maharashtra
Accredited by NAAC with "A+" Grade | NBA - 5 UG Programmes

Thank You !

sachin.shelar@aissmsioit.org